

MIAMI-DADE FIRE RESCUE DEPARTMENT INSPECTION REPORT FIRE PREVENTION BUREAU



9300 NW 41ST STREET, DORAL, FLORIDA 33178-2424 (786) 331-4800

Permit Number: 01121-00015

Inspected: September 22, 2023

Permit Type: Education

Permit Use: Public Licensed Educ. Facility

Permit Status: Inspected / Approved

Inspector: FAI YEUNG Phone: (786) 331-4835

Email: fai.yeung@miamidade.gov

DADE COUNTY PUBLIC SCHOOLS - DCPS

1450 NE 2 AVE ROOM 602 MIAMI, FL 33132

Inspected Address:

DCPS GILBERT PORTER ELEMENTARY PRIMARY **LEARNING CENTER**

15751 - 15751 SW 112 ST MIAMI, FL 33196

Violation(s)

1. Created Code Comply By **Violation Corrected** 09/22/2023 8/30/2022 09/29/2022 FFPC 7th Edition, NFPA 101:

Violation: 16.7.2.2 Failure to conduct or provide documentation of required emergency egress and relocation (Fire) drills.

Correction: Conduct required emergency egress and relocation (Fire) drills, and provide documentation as required by code.

Comment: Code 1201 Provide documentation to Inspector Vicky Manjarres, email: vickym@miamidade.gov

NOTICE OF VIOLATION AND ORDER TO CORRECT

The hazards noted herein are in violation of the Florida Fire Prevention Code and/or Miami-Dade County Code and are deemed to be threats to life safety and/or property. You are hereby ordered to comply with the corrective measures prescribed .

APPEALS: Any person who believes they were incorrectly issued a notice of violation or that the violation cited is not applicable to their occupancy classification or believes aggrieved by any action or decision of this code may appeal to the Miami- Dade County Fire Prevention and Safety Appeals Board by filing a written notice within 30 days of receiving the Notice of Violation and Order to Correct. The appeal request must be submitted in writing to the Secretary of the Board. Information on filing an appeal can be obtained on the web at: http://www.miamidade.gov/fire/request-appeal.asp. Filing of a written notice of appeal shall not stay the effect of any such action or decision which is the subject to the appeal. Section 14-36, Code of Miami-Dade County.

Note: A Life Safety Permit required by Section 14-39, Code of Miami-Dade County, to operate the above named occupancy will be issued upon correction of all outstanding violations and payment of fees assessed. Failure to obtain the required Life Safety Permit will result in enforcement actions including fines, citations, liens and/or orders to cease and desist operation.

Name: LORENA SOMOHANO

Title: Supervisor





How did we do? We would like to hear about it. Scan the QR code to complete a survey.

Page 1 of 1 (01121-00015)

9/22/2023 Printed: Version: