

MIAMI-DADE FIRE RESCUE DEPARTMENT - Inspection Report



FIRE PREVENTION DIVISION
9300 NW 41 STREET, DORAL, FLORIDA 33178
PHONE 786.331.4800 FAX 786.331.4801



PERMIT # 00121-00059

Business Address: (District 37)
 DCPS DR. GILBERT L PORTER ELEMENTARY
 SCHOOL
 15851-15851 SW 112 ST
 MIAMI, FL 33196

Billing Address:
 DADE COUNTY PUBLIC SCHOOLS - DCPS
 1450 NE 2 AVE ROOM 602
 MIAMI, FL 33132

RESULT: Inspected / N.O.V. (30)
Resulted Date: 4/26/22

Permit Type: Education / Public Licensed Educ. Facility.
Inspection Month: May
Inspector:
 VICKY MANJARRES
 (786) 336-6820
 vickym@miamidade.gov

NOTICE OF VIOLATION AND ORDER TO CORRECT

The hazards noted herein are in violation of the Florida Fire Prevention Code and/or Miami-Dade County Code and are deemed to be threats to life safety and/or property. You are hereby ordered to comply with the corrective measures prescribed. Nothing in this report supersedes any previously written, still existing violations for this occupancy.

APPEALS

Any person who believes they were incorrectly issued a notice of violation or that the violation cited is not applicable to their occupancy classification or believes aggrieved by any action or decision of this code may appeal to the Miami-Dade County Fire Prevention and Safety Appeals Board by filing a written notice **within 30 days** of receiving the Notice of Violation and Order to Correct. The appeal request must be submitted in writing to the Secretary of the Board. Information on filing an appeal can be obtained on the web at: <http://www.miamidade.gov/fire/request-appeal.asp>. Filing of a written notice of appeal shall not stay the effect of any such action or decision which is the subject to the appeal. Section 14-36, Code of Miami-Dade County

Please Note: A Life Safety Permit required by Section 14-39, Code of Miami-Dade County, to operate the above named occupancy will be issued upon correction of all outstanding violations and payment of fees assessed. **Failure to obtain the required Life Safety Permit will result in enforcement actions including fines, citations, liens and/or orders to cease and desist operation.**

Viol.	Date Created	Comply by Date	Violation, Correction & Comments
Failure to comply with below violations will result in issuance of a citation			
1	4/26/22	5/26/22	<p>Violation: FFPC 7th Edition, NFPA 72: 14.2.2.2.2 Fire Alarm. Trouble Status. Failure to maintain fire alarm system free of trouble or supervisory conditions.</p> <p>Correction: Have a licensed fire alarm contractor repair fire alarm system to clear any trouble or supervisory condition; provide to the Fire Department documentation from a licensed fire alarm contractor that the violation has been corrected and the system is functioning without any deficiencies..</p> <p>Comments: Code 407 FACP shows trouble: provide documentation dated on or after 4/26/22 showing that Fire Alarm System have been repaired to Inspector Vicky Manjarres, email: vickym@miamidade.gov.</p>
2	4/26/22	5/26/22	<p>Violation: FFPC 7th Edition, NFPA 1: 11.1.5.6 Electrical Safety. Extension Cords. Permanent wiring. Failure to provide proper electrical receptacles..</p> <p>Correction: Remove all extension cords; extension cords shall be not be used as a substitute for permanent wiring..</p> <p>Comments: 803 Wall next to access door to room 806.</p>



We would like feedback on your experience with your Life Safety Inspection. Please take a minute to complete our survey at:
http://bit.ly/mdfr_2tcSXHm

MIAMI-DADE FIRE RESCUE DEPARTMENT - Inspection Report

3	4/26/22	5/26/22	<p>Violation: FFPC 7th Edition, NFPA 1: 11.1.8 Electrical Safety. Covers. Failure to provide proper covers for electrical panels, junction boxes, and receptacles..</p> <p>Correction: Provide covers for all panelboard, switchboards, pull boxes, junction boxes, switches, receptacles, and conduit bodies, compatible with the box or conduit body construction and suitable for the condition of use..</p> <p>Comments: Code 809 Mechanical rooms 001, 003 & 110.</p>
4	4/26/22	5/26/22	<p>Violation: FFPC 7th Edition, NFPA 1: 13.3.3.4.3.1 Fire Protection System. Annual Fire Sprinkler Inspection. Failure to provide fire sprinkler inspection and testing report.</p> <p>Correction: Provide a current complete annual fire sprinkler inspection and testing report clear of any deficiencies or impairments or provide documentation of the repair of any deficiencies or impairments listed thereon.</p> <p>Comments: Code 509 Provide documentation of current Annual Fire Sprinkler Inspection Report showing no deficiencies to Inspector Vicky Manjarres; email: vickym@miamidade.gov.</p>

CUSTOMER SIGNATURE

Title: Agency
Name:

Please Note: A life safety permit will be issued upon compliance of outstanding violations and payment of fees assessed . One (1) re-inspection will be performed at no additional cost. All subsequent re-inspections will be billed at one-half the original permit fee amount.



We would like feedback on your experience with your Life Safety Inspection .
Please take a minute to complete our survey at:
http://bit.ly/mdfr_2tcSXHm